

UltraTEV Plus² Factory Calibration Certificate

EA Technology hereby certifies that the instrument listed below has been measured and calibrated at EA Technology's Asset Management's Laboratories in accordance with procedure 2418/D/01/- documented in a quality system registered to ISO9001:2008. The unit conformed to the test requirements and the results are detailed below:-

Serial Number: UTP2 - 0696

Recommended Calibration Interval*: 12 months

Test Results delete as appropriate

1.	TEV measurement: ± 1 dB	PASS
2.	TEV sensor operation	PASS
3.	Ultrasonic measurement levels: ± 1 dB	PASS
4.	Ultrasonic sensor operation	PASS
5.	Cable PD operation	PASS
6.	microSD operation	PASS
7.	USB operation	PASS
8.	LCD operation	PASS
9.	Touchscreen operation	PASS
10.	Wi-Fi operation	PASS
11.	Photo phase reference operation	PASS
12.	E-field phase reference operation	PASS
13.	NFC operation	PASS
14.	Self-test	PASS
15.	Visual/final inspection	PASS

Signed:



Yuen Weng Heng

Issue Date:

*The recommended calibration interval is based on EA Technology's experience with this product.

Your application may require a different calibration interval dependant on the frequency of use.

EA Technology Asset Management Pte Ltd

8 Ubi Road 2, #03-08 Zervex,
Singapore 408538

tel
fax
web

+65 6634 3591
+65 6634 3590
www.eatechnology.sg

GST / Company Registration No. 201115883W

